

Over current switch, 50A, 3pole+N, type C characteristic, 6 kA



FAZ6-C50/3N 239178 FAZ6-C50/3N



Similar to illustration

## Design verification as per IEC/EN 61439

| · · ·  |                  |   |  |
|--|------------------|---|--|
| Technical data for design verification   |                  |   |  |
| Rated operational current for specified heat dissipation   | I <sub>n</sub>   | А | 50   |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub> | W | 15.3   |
| IEC/EN 61439 design verification   |                  |   |  |
| 10.2 Strength of materials and parts   |                  |   |  |
| 10.2.2 Corrosion resistance  |                  |   | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                  |   | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                  |   | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                  |   | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                  |   | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                  |   | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                  |   | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                  |   | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                  |   | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                  |   |  |
| 10.9.2 Power-frequency electric strength   |                  |   | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                  |   | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                  |   | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                  |   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility  |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function  |                  |   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 6.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

| Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011]) |  |    |         |  |
|--|--|----|---------|--|
| Release characteristic   |  |    | C       |  |
| Number of poles (total)  |  |    | 4       |  |
| Number of protected poles  |  |    | 4       |  |
| Nominal rated current  |  | А  | 50      |  |
| Nominal rated voltage  |  | V  | 230     |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V  |  | kA | 6       |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V  |  | kA | 6       |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V   |  | kA | 10      |  |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V   |  | kA | 10      |  |
| Voltage type   |  |    | AC      |  |
| Current limiting class   |  |    | 3       |  |
| Frequency  |  | Hz | 50 - 60 |  |

| Concurrently switching N-neutral        |    | Yes    |
|---|----|--------|
| Suitable for flush-mounted installation |    | No     |
| Over voltage category                   |    | 3      |
| Pollution degree                        |    | 2      |
| Width in number of modular spacings     |    | 4      |
| Built-in depth                          | mm | m 70.5 |
| Additional equipment possible           |    | Yes    |
| Degree of protection (IP)               |    | IP20   |