

Over current switch, 32A, 1pole+N, type C characteristic, 6 kA

Powering Business Worldwide

Part no. FAZ6-C32/1N Article no. 239081 Catalog No. FAZ6-C32/1N

Similar to illustration

| hnical data for design verification | | | |
|--|------------------|---|--|
| Rated operational current for specified heat dissipation | In | Α | 32 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 4.4 |
| /EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| $10.2.3.3\ Verification\ of\ resistance\ of\ insulating\ materials\ to\ abnormal\ heat\ and\ fire\ due\ to\ internal\ electric\ effects$ | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 6.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011])

| Release characteristic | | | С |
|--|---|----|-----|
| Number of poles (total) | | | 2 |
| Number of protected poles | | | 2 |
| Nominal rated current | , | A | 32 |
| Nominal rated voltage | \ | V | 230 |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V | ŀ | kA | 6 |
| Rated short-circuit breaking capacity Icn EN 60898 at 400 V | ŀ | kA | 6 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V | ŀ | kA | 10 |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | ŀ | kA | 10 |
| Voltage type | | | AC |

| Current limiting class | | 3 |
|---|----|---------|
| Frequency | Hz | 50 - 60 |
| Concurrently switching N-neutral | | Yes |
| Suitable for flush-mounted installation | | No |
| Over voltage category | | 3 |
| Pollution degree | | 2 |
| Width in number of modular spacings | | 2 |
| Built-in depth | mm | 70.5 |
| Additional equipment possible | | Yes |
| Degree of protection (IP) | | IP20 |