DATASHEET - PFIM-25/2/003-A-MW



Residual current circuit breaker (RCCB), 25A, 2p, 30mA, type A

Powering Business Worldwide

Part no. Catalog No. PFIM-25/2/003-A-MW 235424

EL-Nummer (Norway)

0001609311

Similar to illustration

| Delivery program | | | | | |
|------------------------------|-----------------|----|--|--|--|
| Basic function | | | Residual current circuit-breakers | | |
| Number of poles | | | 2 pole | | |
| Application | | | Residual current circuit-breaker for residential and commercial applications | | |
| Rated current | In | Α | 25 | | |
| Rated short-circuit strength | I _{cn} | kA | 10 | | |
| Rated fault current | $I_{\Delta N}$ | Α | 0.03 | | |
| Туре | | | Type A | | |
| Tripping | | s | non-delayed | | |
| Product range | | | PFIM | | |
| Sensitivity | | | Pulse-current sensitive | | |
| Impulse withstand current | | | Partly surge-proof 250 A | | |

Technical data

| F | ectrica |
|---|---------|
| | OULIUU |

| Standards | | | IEC/EN 61008 | | |
|--|--------------------|------|-------------------------|--|--|
| Rated operational voltage | U _e | V | | | |
| | U _e | V AC | | | |
| Rated operating voltage | U _e | V AC | 230 | | |
| Rated frequency | f | Hz | 50 | | |
| Limit values of the operating voltage | | | | | |
| Test circuit | | V AC | 196 - 264 | | |
| Sensitivity | | | Pulse-current sensitive | | |
| Rated insulation voltage | Ui | V | 440 | | |
| Rated impulse withstand voltage | U _{imp} | kV | 4 | | |
| Rated short-circuit strength | I _{cn} | kA | 10 | | |
| Rated making and breaking capacity / Rated residual making and breaking capacity | $I_m/I_{\Delta m}$ | Α | 500 | | |
| lifespan | | | | | |
| Electrical | Operations | | ≧ 4000 | | |
| Mechanical | Operations | | ≧ 20000 | | |
| References | | | | | |

References

| Z-HK 248432 |
|--------------------|
| Z-NHK 248434 |
| Z-FW/LP 248296 |
| KLV-TC-2 276240 |
| Z-RC/AK-2MU 285385 |
| |

Machanical

| Wechanical | | |
|--------------------------|----|---|
| Standard front dimension | mm | 45 |
| Device height | mm | 80 |
| Built-in width | mm | 35 (2TE) |
| Mounting | | Quick attachment with 2 latch positions for DIN-rail IEC/EN 60715 |
| Degree of Protection | | IP40, IP54 (with moisture-proof enclosure) |
| Terminals top and bottom | | Open mouthed/lift terminals |
| Terminal protection | | DGUV VS3, EN 50274 |
| Terminal cross-section | | |

| Solid | mm^2 | 1.5 - 35 |
|--|-----------------|---|
| Stranded | mm ² | 2 x 16 |
| Thickness of busbar material | mm | 0.8 - 2 |
| Permissible storage and transport temperatures | °C | -35 - +60 |
| Climatic proofing | | 25-55°C/90-95% relative humidity according to IEC 60068-2 |
| Thickness of busbar material | mm | |
| Material thickness | mm | 0.8 - 2 |

Design verification as per IEC/EN 61439

| Design verification as per IEG/EN 01439 | | | |
|--|-------------------|----|--|
| Technical data for design verification | | | |
| Rated operational current for specified heat dissipation | In | Α | 25 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 2 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 55 |
| | | | Starting at 40 °C, the max. permissible continuous current decreases by 3% for every 1 °C |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | | | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | | | Is the panel builder's responsibility. |
| 10.9 Insulation properties | | | |
| 10.9.2 Power-frequency electric strength | | | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | | | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | | | Is the panel builder's responsibility. |
| 10.10 Temperature rise | | | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | | | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | | | |

Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Residual current circuit breaker (RCCB) (EC000003)

Electric engineering, automation, process control engineering / Electrical installation, device / Residual current protection system / Residual current circuit breaker (RCCB) (ecl@ss10.0.1-27-14-22-01 [AAB906014])

| (ecl@ss10.0.1-27-14-22-01 [AAB906014]) | | |
|--|----|-----|
| Number of poles | | 2 |
| Rated voltage | V | 230 |
| Rated current | Α | 25 |
| Rated fault current | mA | 30 |

| Rated insulation voltage Ui | V | 440 | |
|---|----|----------|--|
| Rated impulse withstand voltage Uimp | kV | 4 | |
| Mounting method | | DIN rail | |
| Leakage current type | | Α | |
| Selective protection | | No | |
| Short-time delayed tripping | | No | |
| Short-circuit breaking capacity (Icw) | kA | 10 | |
| Surge current capacity | kA | 0.25 | |
| Frequency | | 50 Hz | |
| Additional equipment possible | | Yes | |
| With interlocking device | | Yes | |
| Degree of protection (IP) | | IP20 | |
| Width in number of modular spacings | | 2 | |
| Built-in depth | mr | 70.5 | |
| Ambient temperature during operating | °C | -25 - 40 | |
| Pollution degree | | 2 | |
| Connectable conductor cross section multi-wired | mr | 1.5 - 16 | |
| Connectable conductor cross section solid-core | mr | 1.5 - 35 | |
| | | | |